


PTW Safety Checklist No. 18



USE OF NON IS & ELECTRICAL EQUIPMENT EQUAL TO OR LESS THAN 230V

Other Checklists that may be relevant:		17, 27
Permit Number:		Date:
Rev 3.0	Issue Date: 01/09/2020	Authorised By: PSM

USING 230V ELECTRICAL EQUIPMENT:

- | | | Y | N | N/A |
|---|---|--------------------------|---|--------------------------|
| 1 | All equipment checked and found to be in good condition with a current test tag.
NOTE: These tags must be fitted by a registered electrician. | <input type="checkbox"/> | | |
| 2 | An ELCB or RCD must be used. | <input type="checkbox"/> | | <input type="checkbox"/> |
| 3 | Cables run through a hazardous area are clearly identified as suitable for hazardous areas. | <input type="checkbox"/> | | <input type="checkbox"/> |
| 4 | Cables are adequately protected when external damage is possible e.g. crossing roadways. | <input type="checkbox"/> | | <input type="checkbox"/> |

USING BATTERY OPERATED EQUIPMENT:

- | | | Y | N | N/A |
|---|---|--------------------------|---|--------------------------|
| 5 | All equipment has been checked and found to be in good condition. | <input type="checkbox"/> | | |
| 6 | Batteries must not be left unattended in hazardous areas. | <input type="checkbox"/> | | <input type="checkbox"/> |
| 7 | Batteries must have a specific gas test recorded when changing out from tool. | <input type="checkbox"/> | | <input type="checkbox"/> |