


PTW Safety Checklist No. 26



USE OF VACUUM TRUCK (GULLY SUCKER)

Other Checklists that may be relevant:		24 , 25
Permit Number:		Date:
Rev 2.0	Issue Date: 13/12/2017	Authorised By: PSM

NOTE: This checklist to be used in conjunction with [Checklist 24](#).

PRIOR TO PERMIT ISSUE:

- | | | Y | N | N/A |
|---|---|--------------------------|---|--------------------------|
| 1 | Dangerous Goods / HSNO placards are displayed on the truck. | <input type="checkbox"/> | | |
| 2 | You have read and understood the contents of the Safety Data Sheets (SDS) for the substance(s) being handled. | <input type="checkbox"/> | | |
| 3 | Disposal location for product being collected has been confirmed with PI.
Location: _____ | <input type="checkbox"/> | | |
| 4 | If the liquid / waste is to be removed from site, discuss the waste disposal route with PI. Waste Management Procedure covers this process. | <input type="checkbox"/> | | <input type="checkbox"/> |

PREPARATION:

- | | | | | |
|---|---|--------------------------|--|--------------------------|
| 5 | In the event of a site alarm, the engine is to be turned off with key left in the ignition and personnel are to proceed to the muster point by foot. | <input type="checkbox"/> | | <input type="checkbox"/> |
| 6 | Is this system one that may contain mercury contamination? (Refer to the Kapuni Site Mercury Register). If the answer is yes, refer to Standard Operating Procedure (SOP) STA-01.43 and PTW Checklist 25 . | <input type="checkbox"/> | | <input type="checkbox"/> |
| 7 | Connect the earth continuity cable from the Gully Sucker to a suitable plant earth point. Record result of continuity test on permit form (<10Ω). | <input type="checkbox"/> | | |
| 8 | Ensure all vapours are vented away from people and any potential ignition sources including the truck. | <input type="checkbox"/> | | |
| 9 | Hoses in good condition and are within current certification period. | <input type="checkbox"/> | | |